

Test Report

Quality Standard		Parameters as desired				
Issued to	-	Sherwood Convent School, L Block, Plot 2102, DLF City, Phase-2,				
Kind attn.	-	Sector 25, Gurgaon-122008				
Analysis no.	-	Mr. 26052106				
Nature of Sample	-	Water Sample marked Drinking-R.O				
Sample received on	-	21 st May 2026				
Report Date	-	25 th May 2026				
Analysis Dates	-	21 st May 2026 to 25 th May 2026				
Sample receipt	-	Picked by Lab				
Sample Packing	-	Sterilized and Pet Bottles				

	PARAMETER	UNIT	RESULT	TEST METHOD	LIMITS	
					Desired	Permissible (in absence of alternate source)
General	Color	Hazen	05	IS 3025 Part 4	05	25
	Odor	Unit Less	Unobjectionable	IS 3025 Part 5	Unobjectionable	Unobjectionable
	Taste	Unit Less	Agreeable	IS 3025 Part 6	Agreeable	Agreeable
Bacteria	Coliform	CFU/100ml	Absent	IS1622	Absent	Absent
	E.Coli	CFU/100ml	Absent	IS1622	Absent	Absent
Physical	pH	Unit Less	7.71	IS 3025 Part 11	6.5-8.5	No Relaxation
	Conductivity	microS at 25°C	148	IS 3025 Part 14	...	---
	Turbidity	NTU	0.90	IS 3025 Part 10	5	10
	Total Dissolved Solids	mg/l	78	IS 3025 Part 16	500	2000
Chemical	M. Alkalinity as CaCO ₃	mg/l	41.1	IS 3025 Part 23	200	600
	Total Hardness as CaCO ₃	mg/l	55.9	IS 3025 Part 21	300	600
	Chlorides as Cl	mg/l	14.5	IS 3025 Part 32	250	1000
	Total Iron as Fe	mg/l	0.01	IS 3025 Part 53	0.3	1.0
	Residual Free Chlorine	mg/l	Nil	IS 3025 Part 35	0.20	--

Remarks: The no. of parameters tested is 14 only. The results indicate that the Quality of Water may be considered to be within the desired limits for Drinking as per IS:10500, in regard to the parameters tested. The report is issued subject to the terms & conditions as mentioned overleaf.

Chemist _____

Authorized Signatory _____

For Sherwood Convent School

Manager

Reviewed by Sign : _____
Designation : Quality Analyst




Principal

Sherwood Convent School
Registration No. 530205



QUALITY LAB is a trademark and fully owned unit of **Quality Analyst & Labs Pvt. Ltd.**
Office : 382, Vardhman Charve Plaza-5, Plot No. 20, KP Block Commercial Centre, Pitam Pura, New Delhi-110088
Exclusive representatives in South Asia for Green Seal, Inc., 1001, Connecticut Avenue, NW, Suite, 827, Washington, DC, USA
Exclusive representatives in India for Sens Aqua, Naeringshagen No. 7340, OPPDAL, Norway
Exclusive representatives in India for Femko Technical Control and Certification Ltd., Izmir, Turkey for CE Marking

Test Report

Quality Standard			Parameters as desired			
Issued to	-	Sherwood Convent School, L Block, Plot 2102, DLF City, Phase-2, Sector 25, Gurgaon-122008				
Kind attn.	-	Mr.				
Analysis no.	-	26052105				
Nature of Sample	-	Water Sample marked Drinking-Aquaguard				
Sample received on	-	21 st May 2026				
Report Date	-	25 th May 2026				
Analysis Dates	-	21 st May 2026 to 25 th May 2026				
Sample receipt	-	Picked by Lab				
Sample Packing	-	Sterilized and Pet Bottles				

	PARAMETER	UNIT	RESULT	TEST METHOD	LIMITS	
					Desired	Permissible (in absence of alternate source)
General	Color	Hazen	05	IS 3025 Part 4	05	25
	Odor	Unit Less	Unobjectionable	IS 3025 Part 5	Unobjectionable	Unobjectionable
	Taste	Unit Less	Agreeable	IS 3025 Part 6	Agreeable	Agreeable
Bacteria	Coliform	CFU/100ml	Absent	IS1622	Absent	Absent
	E.Coli	CFU/100ml	Absent	IS1622	Absent	Absent
Physical	pH	Unit Less	7.97	IS 3025 Part 11	6.5-8.5	No Relaxation
	Conductivity	microS at 25*c	280	IS 3025 Part 14	...	---
	Turbidity	NTU	1.0	IS 3025 Part 10	5	10
	Total Dissolved Solids	mg/l	147	IS 3025 Part 16	500	2000
Chemical	M. Alkalinity as CaCO3	mg/l	85.2	IS 3025 Part 23	200	600
	Total Hardness as CaCO3	mg/l	116	IS 3025 Part 21	300	600
	Chlorides as Cl	mg/l	23.3	IS 3025 Part 32	250	1000
	Total Iron as Fe	mg/l	0.01	IS 3025 Part 53	0.3	1.0
	Residual Free Chlorine	mg/l	Nil	IS 3025 Part 35	0.20	--

Remarks: The no. of parameters tested is 14 only. The results indicate that the Quality of Water may be considered to be within the desired limits for Drinking as per IS:10500, in regard to the parameters tested. The report is issued subject to the terms & conditions as mentioned overleaf.

Chemist

Authorized Signatory

For Sherwood Convent School

Reviewed by Sign : 
Designation : Quality Analyst

Manager


Principal
Sherwood Convent School
Affiliation No. 530205

QUALITY LAB is a trademark and fully owned unit of Quality Analyst & Labs Pvt. Ltd.

Office : 382, Vardhman Charve Plaza-5, Plot No. 20, KP Block Commercial Centre, Pitam Pura, New Delhi-110088

Exclusive representatives in South Asia for Green Seal, Inc., 1001, Connecticut Avenue, NW, Suite, 827, Washington, DC, USA

Exclusive representatives in India for Sens Aqua, Naeringsshagen No. 7340. OPPDAL, Norway

Exclusive representatives in India for Femko Technical Control and Certification Ltd., Izmir, Turkey for CE Marking